

Attestation

WELL Building Standard™

On 7 September 2021, Eurofins Product Testing A/S received a sample of a waterproofing membrane with the product name:

SikaTop-107 Seal TH

supplied by

Sika (Thailand) Ltd.

The sample was supplied as being representative of the manufactured product. Sampling, testing and evaluation were performed in accordance with the CDPH 01350 and ASTM D2369 test standards (See test report no. 392-2021-00437102_H_EN and 392-2021-00437104_XG_EN).

The tested product complies with the requirements of WELL v2 Feature X12 Short-Term Emission Control: Part 1 and 2 by complying with:

VOC emissions specifications:

- The requirement of Part 1 by complying with the CDPH 01350 v 1.2 (January 2017)

VOC content specifications:

- The requirement of part 2 by complying with the South Coast Air Quality Management District (SCAQMD) Rule 1113 (2016).

13 October 2021



Rasmus Verdier
Analytical Service Manager



Janne Rothmann Norup
Analytical Service Manager

The International WELL Building Institute (IWBI) is a public benefit corporation whose mission is to improve human health and well-being in buildings and communities across the world through its WELL Building Standard (WELL). WELL™ and the related logo are trademarks owned by the IWBI and are used with permission.